



Office of the
Haldia Municipality

Dr. B.R. Ambedkar Bhawan, Administrative Building, City Centre
P.O.- Debhog, Haldia, Purba Medinipur, West Bengal

Grievance Whatsapp No.

8250665469

Fax : 03224-252154

E-mail : haldiamunicipality@gmail.com

Memo No. : 79/HM/2025

Date : 08.01.25


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

To Whom it My Concern

This is to certify that an inspection comprising of officials Haldia Municipality, Haldia, West Bengal has inspected **Sudhir Institute**, Brajanathchak, Jl. No.-196, Plot No: 269, P.O.-Haldia Port, P.S.-Haldia, Dist-Purba Medinipur, Pin-721607, West Bengal on 02/01/2025 and has found that the School has safe drinking water facilities for the students and members of the staff of the Institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State Government.

The above certificate is valid for a period of one year from the date of issuance.




08/01/25

(Sandip Kumar Bhowmik)

Sanitary Inspector

Haldia Municipality

Sanitary Inspector

Haldia Municipality

ABHYUDAYA, HALDIA SUB-DISTRICT LABORATORY

Public Health Engineering Directorate Government of West Bengal

Certificate No. : NABL - DWT - 00300 + Valid till : 07.06.2025

Vill - Deulpota, P.O.- Barbasudevpur, Block - Haldia, Dist - Purba Medinipur, PIN - 721645

TEST REPORT

Date : 16.12.2024

Sender Name : To, HM/Incharge/Director

Sudhir Institute (High School)

Location - Brajanathchak, Haldia Port, Haldia, Purba Medinipur

Sample Particulars :

Sample Description : 500 ml NA

Date of Receive of Sample : 13.12.2024

Date of Starting of Analysis : 13.12.2024

Type of Sample : Drinking Water

Date of completion : 14.12.2024

Sample Collection by : Gurupada Bhowmik

Sample tested as received

Temp. - 21 °C

TEST RESULTS

Sl No	Test Parameters	Unit	Test Method	IS : 10500 : 2012		Result	Remarks
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternative Source (Max)		
1	pH	-	IS 3025 Part II):1983, Electronic method	6.5 - 8.5	No Relaxation	7.62	Safe
2	Conductivity	µS/Cm	is 3025 (Part 16) : 1984 Gravimetric Method	-	-	2055	Safe
3	Total Dissolved Solid	mg/l	is 3025 (Part 16) : 1984 Gravimetric Method	500	2000	1096	Safe
4	Turbidity	NTU	IS 3025 (Pt 16): 1984 Nephelometric Turbidity Meter	1	5	1.15	Safe
5	Iron	mg/l	Spectro Photometric Method	0.1	1	0.17	Safe
6	Manganese	mg/l	Spectro Photometric Method	0.1	0.3	0.02	Safe
7	Total Hardness(as CaCO ₃)	mg/l	IS 3025 (Part 21): 1983 EDTA Titrimetric Method	200	600	340	Safe
8	Chloride(as Cl)	mg/l	IS 3025 (Part 32): 1988 Argentometric Method	250	1000	570.03	Safe
9	Colour	HU	Is 3025(part 4): 1983 Potassium chloroplatinate (visual Comparison)Method Reaffirmed (part 21):2002 (Amendment-2007)	5	15	-	-
10	Odour	Qualitative	IS 3025 (part5): 1983Reaffirmed (part21):2002	Agreeable	Agreeable	-	-
11	Taste	Qualitative	IS 3025(part 7): 1984 Taste Threshold Reaffirmed(Part 21):2002	Agreeable	Agreeable	Agreeable	Safe
12	Total Coliform		MFT	Absent	Absent	Absent	Safe
13	Fecal Coliform		MFT	Absent	Absent	Absent	Safe

Surendrasekhar Behera

Laboratory Analyst

Abhyudaya Haldia Sub District Lab.

Anupam Mahto

Secretary

Abhyudaya Haldia Sub District Lab.

ABHYUDAYA, HALDIA
Vill - Deulpota, P.O.- Barbasudevpur
Purba Medinipur